

CERTIFICATE OF CONFORMITY

Certificate No.: LC20759-1

Date Issued: February 9, 2022

Project No.: 20759

Certification System: Type 3
(ISO / IEC 17067)

Client No.: LC1231751

Applicant: Victron Energy B.V.
De Paal 35
1351 JG Almere Haven
Netherlands



Kaushik Shukla

Issued by: _____
Certification Manager

Products:

- Phoenix Inverter
- Models: MultiPlus II 12/3000/120-50 2x120V

Model/Type(s):	MultiPlus-II 12-3000-120-50 2x120V
Rating and main characteristics:	12-3000-120-50 2x120V
<u>INVERTER</u>	
Input voltage range (V DC)	9,5 – 17
Output	Output voltage: 120 VAC ± 2% Frequency: 60 Hz ± 0,1% (can be adjusted to 50Hz)
Cont. output power at 25°C (VA) (non linear load, crest factor 3:1)	3000
Cont. output power at 25°C (W)	2400
Cont. output power at 40°C (W)	2200
Cont. output power at 65°C (W)	1700
Peak power (W)	5500
<u>CHARGER</u>	
AC Input	Split phase: 180-280 VAC 45 – 65 Hz Single phase: 90-140 VAC 45 – 65 Hz
Charge voltage 'absorption' (V DC)	14,4
Charge voltage 'float' (V DC)	13,8
Storage mode (V DC)	13,2
Charge current house battery (A) (at 25°C ambient)	120

The 'C' and 'US' indicators adjacent to the LabTest Certification Mark shall signify that the product has been evaluated by an accredited laboratory to the applicable Canadian and US Standards. The subject area shall be displayed with the LabTest Certification Mark to identify the Standard Number, and Revision Level.

Applicant: Victron Energy B.V.

Certificate No.: LC20759-1

Applicable requirements:

- UL 458 6th Edition

Conditions of acceptability:

- None

General Note:

- Refer to LC Listing Report No. 10.00.20759-1_Rev0



ISO 17020

ISO 17025

ISO 17065

The 'C' and 'US' indicators adjacent to the LabTest Certification Mark shall signify that the product has been evaluated by an accredited laboratory to the applicable Canadian and US Standards. The subject area shall be displayed with the LabTest Certification Mark to identify the Standard Number, and Revision Level.